Page
)

\mathbf{R}	Exit
	Lights

EXIT LIGHTS - MONTHLY INSPECTION (Health Care & Ambul)

INSPECTOR	DATE COMPLETED

<u>VISUAL INSPECTION</u> (per Life Safety Code, NFPA 101-2000 ed, 7.10.9.1)

- 1. Visually inspect at max 30 day interval from the previous month
- 2. Check that the illumination source is operational. Illumination can be either an internal or external source of emergency power.
- 3. Confirm the sign is readily visible from all distances away and no part of the wording is blocked (LSC 7.10.1.7)

ID # Name	Type Device	Location	Resu Pass	<u>lts</u> Fail	If Devices Fails, Enter <u>Corrective Action</u>
ivame	Device	Location			<u>corrective Action</u>