MONTHLY GENERATOR EXERCISING Who Performed Facility: Date **Generator Information** Generator ID: Location of Generator: Nameplate kW: kW Fuel Number of Phases (1 or 3): On-Site Fuel Cap Operating Voltage: Volts Max Run Duration: Nameplate Full Load Amperes (FLA): **Amps** Names of all ATS(s) fed by this Generator: **Prior to Start-Up: VISUAL TEST** Result of Inspection Check Belt Condition & Tension (fan, pump, alt) Check Battery Posts & Case for Corrosion Cell: 2 3 4 5 6 Measure Battery Specific Gravity in each cell Х Check Battery Charger & Rate Х Check Battery Equalize Charge Х Oil Level Reading Result per NFPA 99(99), 3-4.4 or 3-5.4, **GENERATOR EXERCISE** Pass If: Difference Pass - Fail and NFPA 110(99), 6-3 & 6-4 Date of Test: at least 20, but less than 40 days Date of Prior Test days Time ATS Test Button Pushed AM/PM at least 30 min Time ATS Transfered Back to Normal AM/PM Min Time the Generator Shut Down AM/PM Min at least 5 min # Seconds between Pushing Test & ATS max 10 sec Transfer (Use stopwatch) rotate ATS used to Name of ATS Used to Start Gen: start Names of Other ATS electrically All ATS Exercised transferred to emerg & back Operational Checks: Oil Pressure: psi (Normal=_ 0 F Oil Temp: (Normal= Water Temperature: (Normal=___ **Exhaust Temperature:** (Normal= Air Intake Louver Opened Properly? Radiator Fan Cycled On/Off? Remote Annunciator Indicates Operation? Gen in Auto Position at End? USE ONLY **ONE** OF THE FOLLOWING 3 METHODS Generator Load Check Method #1: 30% of Nameplate Amps (from above): Avg Load at least: **Average Amps** Result L1 Amperage (Leg to Leg): (Sum÷3) (FLA x .3) Pass - Fail amps L2 Amperage (Leg to Leg): amps L3 Amperage (Leg to Leg): amps amps amps Method #2: Min Exhaust Gas Temp Mfgr Min Exh Gas Temp: ⁰F > Actual Exhaust Gas Temperture:

Method #3: Annual Load Bank (Note: OK in lieu of 30% load for Diesel only, NOT Nat Gas)

Generator