EXIT LIGHT MONTHLY INSPECTIONS

	LLSC Form
M	EXIT LIGHTS

2	~	. 1
- a	೯೮	: т

Facility:

EXIT LIGHT Visual Inspection: Tour the building using the EXIT LIGHT DRAWING (new drawing each month) Inspections must take place a MAXIMUM of 30 days from the previous month's inspection.

Check each exit sign/light for the following.

Code Ref: NFPA 101 (2012 ed) §7.10.9.1 §7.10.1.8

- 1. Check that the illumination source is operational. The source of light can be internal to the exit sign or an external light (must be on emergency power) that shines on the exit sign.
- 2. Confirm that the sign is readily visible from all distances away from the sign as you walk up. No portion of the word "EXIT" may be blocked by decorations, other signs, pipes, or any other hanging items.

If light is satisfactory, place a small "OK" next to it on the drawing.

If it fails, CIRCLE the exit light symbol on the drawing & mark an "F" next to it. On the next page write the Exit light ID & location, describe describe the problem and corrective action taken.

Total Qty	Floor	Wing	Location Name	# Internal Illuminated	# external Illuminated	# Passed	# Failed	# Corrected & Retested
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					
			See Drawing for Locations					