

# FIRE EXTINGUISHER MONTHLY INSPECTIONS



Year

Facility

**FIRE EXTINGUISHER Visual Inspection:**

<b><u>NFPA 10-2010</u></b> § 7.2.1.2 & 7.2.2	<b><u>Joint Commission</u></b> EC.02.03.05 EP 15
---	---

Extinguishers must be inspected at approximately 30 day intervals from the previous month for the following:

1. Extinguisher is located in its designated position
2. Nothing Visually or physically obstructs access to the extinguisher (use zero tolerance)
3. Pressure gauge reading or indicator in the operable range or position
4. Fullness determined by weighing or hefting for self-expelling type extinguishers, cartridge-operated extinguishers, and pump tanks
5. Condition of tires, wheels, carriage, hose, and nozzle for wheeled extinguishers?
6. Indicator for nonrechargeable extinguishers using push-to-test pressure indicators?
7. If subject to damage, Inspection includes - Verify that operating instructions on nameplates are legible and face outward
8. If subject to damage, Inspection includes - Check for broken or missing safety seals and tamper indicators
9. If subject to damage, Inspection includes - examine for obvious physical damage, corrosion, leakage, or clogged nozzle

If All items are satisfactory, initial and date (mo/day/hr) on the tag on the extinguisher, inspection checklist, or an electronic method, per 7.2.4.3; 7.2.4.4  
 Inspection records must be available for at least the prior 12 months, per 7.2.4.5  
 If any unit has a deficiency, record below and inform supervisor; Immediate corrective action must be taken & documented, per 7.2.3, 7.2.4.1

Tags on extinguishers are used to document inspections rather than the list below

Yes 
                         
 No

Describe Abnormal Condition:				
	ID #	Date (Mo/Day)	Inspector	Problem/Corrective Action
1				
2				
3				
4				
5				
6				

# FIRE EXTINGUISHER MONTHLY INSPECTIONS



Year

Facility

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Date of Day:												
Inspector:												

Location/ID:	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1												
2												
3												
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												