

## INVENTORY OF CODE INTERPRETATIONS

Topic Keywords	Summary of Topic	Document & Link (Click to View)	AHJ*
<b>Alarm Monitoring</b> Service Cannot Confirm Fire	Cannot delay dispatching fire dept to call facility to confirm a fire (K51)	<a href="#">DHS 08-001-Life Safety Information</a>	4★
<b>Alarm Transmission</b> Documented Testing	Must document quarterly fire alarm signal transmission testing (K52)	<a href="#">DHS 08-001-Life Safety Information</a>	4★
<b>Alcohol Based Hand Rub</b> Install requirements	CMS requirements on ABHR installation	<a href="#">CMS S&amp;C-05-33-Alcohol Based Hand Rub Requirements</a>	4★
<b>Alcohol Based</b> Hand Rubs	ABHR Install Clarification	<a href="#">DQA Interpretation NFPA 101-1</a>	4★
<b>Alcohol Based</b> Hand Rubs, Final Rule	CMS describes how & where ABHR may be used	<a href="#">CMS S&amp;C-07-01-Alcohol Based Hand Rubs-Final Rule &amp; Battery Smoke Alarms</a>	4★
<b>Alcohol Based</b> Skin Preparations, anesthetizing locations	Risk reduction methods for safe use of ABSP in in/out patient anesthetizing locations in hospitals & ASC	<a href="#">CMS S&amp;C-07-11-Alcohol-based Skin Prep in Anesthetizing Locations</a>	4★
<b>Ambulance</b> Enclosure	Ambulance Wall Rating Requirements	<a href="#">DQA Interpretation NFPA 101-2</a>	4★
<b>Anesthetizing locations,</b> Alcohol Based Skin Preparations	Risk reduction methods for safe use of ABSP in in/out patient anesthetizing locations in hospitals & ASC	<a href="#">CMS S&amp;C-07-11-Alcohol-based Skin Prep in Anesthetizing Locations</a>	4★
<b>Anesthetic Smoke</b> Venting	Smoke venting requirements in anesthetic use spaces	<a href="#">DQA Interpretation NFPA 99-1</a>	4★
<b>Auto Flush Bolt</b> on Inactive Leaf	Need reliable latch on double doors of normally occupied rm (K18)	<a href="#">DHS 08-001-Life Safety Information</a>	4★
<b>Baseboard Heaters</b>	Baseboard heater operational requirements for CBRFs, FDD, LTC, RCAC	<a href="#">DSL-BQA-01-023-Baseboard Heaters</a>	4★
<b>Bathroom Air Makeup,</b> from Corridor	Clarifies acceptable amount of incidental air movement to/from corridor	<a href="#">CMS S&amp;C-06-18-Air Movement in Corridors; Plenum Waiver</a>	4★
<b>Battery Backup Power</b> in ASC's	Requirements for Type I Essential Electrical Sys with generator in ASC's	<a href="#">CMS S&amp;C-07-21-Generators in ASC's</a>	4★
<b>Candels:</b> Culture Change, Regulatory Q&A in LTC	Answers from CMS on questions they received on Handrails, Nurse Call Sys , Corridor Width, Egress Concealment, Candles (Q14)	<a href="#">CMS S&amp;C-07-07-Culture Changes Regulatory Q&amp;A</a>	4★
<b>Canopy</b> Sprinkler Requirements	CMS clarifications on providing fire protection to a canopy(Q3); Auto load/unload not considered storage	<a href="#">CMS S&amp;C-05-38-Wardrobe/Closet &amp; Canopy Sprinkler Requirements; Exit Discharge Surfacing</a>	4★
<b>Canopy/Overhang</b> Sprinkler Requirements	CMS requirements on sprinkling of canopies & overhangs; use of FSES & waivers	<a href="#">CMS S&amp;C-07-29-Canopy &amp; Overhang Sprinklers; Use of FSES</a>	4★
<b>Ceiling System</b> Smoke- tightness	Compromised ceiling system are major concern of sprinkler installation (K56)	<a href="#">DHS 08-001-Life Safety Information</a>	4★
<b>Closet/Wardrobe</b> Sprinkler Requirements	CMS clarifications on providing fire protection to closets; wardrobes may be furniture (Q1)	<a href="#">CMS S&amp;C-05-38-Wardrobe/Closet &amp; Canopy Sprinkler Requirements; Exit Discharge Surfacing</a>	4★
<b>Constr Plan</b> Form Update	Submit plans on Updated F62333 application	<a href="#">DHS 12-019-New Lean Application</a>	4★

\*Estimate of acceptability by CMS/DQA Surveyor

because of who generated:

#★ : 4 = CMS/DQA; 3=TJC/NFPA; 2=Other AHJ; 1=Non-AHJ

## INVENTORY OF CODE INTERPRETATIONS

Topic Keywords	Summary of Topic	Document & Link (Click to View)	AHJ*
<b>Constr Plan</b> Submission	Submit plans to Milw Office	<a href="#">DHS 13-005-Submission of Constr Plans</a>	4★
<b>Construction Type</b> in CBRF	Construction Type for Class C CBRF	<a href="#">DHS 11-027-Constr Requirements for New Class C CBRF</a>	4★
<b>Corridor Door</b> Astragal	Gaps >1/8" require astragal (K18)	<a href="#">DHS 08-001-Life Safety Information</a>	4★
<b>Corridor Doors</b> , Permitted Gaps	Door gap clearances defined in sprinkled or non-sprinkled smoke compartments	<a href="#">CMS S&amp;C-07-18-Permitted Gaps in Corridor Doors</a>	4★
<b>Corridor Neutral</b> Airflow	Clarifies acceptable amount of incidental air movement to/from corridor	<a href="#">CMS S&amp;C-06-18-Air Movement in Corridors; Plenum Waiver</a>	4★
<b>Corridor Plenums</b>	MWC restates CMS policy of citing corridor plenums; Corridor conditioning is not a plenum (K67)	<a href="#">CMS MWC 05-03-Corridor Plenum for LTC, Midwest Consortium</a>	4★
<b>Corridor Seating</b> -Life Safety Code-2012 edition Waiver	Waivers possible to corridor chairs, open kitchens, direct-vent fireplaces, combustible decorations	<a href="#">CMS S&amp;C-12-21-LSC-Instructions Concerning Waivers</a>	4★
<b>Corridor Width</b>	Corridor wall-mounted equipment clarifications (max 6" projection)	<a href="#">CMS S&amp;C-10-18-Corridor Width</a>	4★
<b>Corridor Width</b> in CBRF	Corridor Width in Class C CBRF	<a href="#">DQA Interpretation CBRF 83-1</a>	4★
<b>Corridor Width</b> , Wall Mounted Computers	Corridor mounted computer touch screens okay if project max 3-1/2" & min 60" above floor	<a href="#">CMS S&amp;C-04-41-Corridor Mounted Computer Touch Screens</a>	4★
<b>Corridor Width</b> : Culture Change, Regulatory Q&A in LTC	Answers from CMS on questions they received on Handrails, Nurse Call Sys , Corridor Width (Q9), Egress Concealment	<a href="#">CMS S&amp;C-07-07-Culture Changes Regulatory Q&amp;A</a>	4★
<b>Critical Access Hospital</b> , Bed Increase to 25	CAH can increase from 15 to 25 acute-care beds	<a href="#">CMS S&amp;C-04-14-Critical Access Hospital Increase to 25 Beds</a>	4★
<b>Culture Change</b> , Regulatory Q&A in LTC	Answers from CMS on questions they received on Meals, Food Sources, RNs, QA, HIPPA, Handrails, Nurse Call Sys, Posting of SOD, Corridor Width, Egress Concealment, Dining Together, Candles, Tablecloths, etc	<a href="#">CMS S&amp;C-07-07-Culture Changes Regulatory Q&amp;A</a>	4★
<b>Decorations, Combustible</b> -Life Safety Code-2012 edition Waiver	Waivers possible to corridor chairs, open kitchens, direct-vent fireplaces, combustible decorations	<a href="#">CMS S&amp;C-12-21-LSC-Instructions Concerning Waivers</a>	4★
<b>Dialysis Units</b> -Life Safety Code Effective Date	LSC to be used for new Dialysis Units after Feb, 2009, with exceptions	<a href="#">CMS S&amp;C-09-24-ESRD LSC Effective Date</a>	4★
<b>Egress Concealment</b> : Culture Change, Regulatory Q&A in LTC	Answers from CMS on questions they received on Handrails, Nurse Call Sys , Corridor Width, Egress Concealment (Q10)	<a href="#">CMS S&amp;C-07-07-Culture Changes Regulatory Q&amp;A</a>	4★

\*Estimate of acceptability by CMS/DQA Surveyor

because of who generated:

#★ : 4 = CMS/DQA; 3=TJC/NFPA; 2=Other AHJ; 1=Non-AHJ

## INVENTORY OF CODE INTERPRETATIONS

Topic Keywords	Summary of Topic	Document & Link (Click to View)	AHJ*
<b>Electrical Requirements</b> for Ventilator Dependiant Residents	Facility requirements prior to admitting a resident who is depenent on electrically powered equip	<a href="#">DSL-BQA-00-016-Planning to Admit Ventilator Dependent Residents or Persons with Related Conditions</a>	4★
<b>Elevator Machine Rm</b> Suppression	Alternative Suppression Sys for Elevator Machine Rooms	<a href="#">DHS 11-012-Alternative Suppression Sys for Elevator Machine Rooms</a>	4★
<b>Emergency Hotline</b> Phone Number to DHS	24-hr Hot Line established 1-608-258-0099 to report all disasters, fires	<a href="#">DDES-BQA-06-008-24-Hr Emergency Hotline</a>	4★
<b>Emergency Preparedness</b> - CMS Website	CMS website on Emergency Preparedness	<a href="#">CMS Emergency Preparedness Website</a>	4★
<b>Emergency Preparedness</b> FAQ by CMS	CMS developed a Frequently Asked Question document with all-hazard approach	<a href="#">CMS S&amp;C-08-01-Emerg Preparedness FAQ Document</a>	4★
<b>Emergency Preparedness</b> FAQ by CMS	Frequently asked questions on various CMS topics	<a href="#">CMS FQA Document 1</a>	4★
<b>Equipment Maintenance</b> - Hospital	Mfgr recommended frequencies may be adjusted for medical & facility equip; Must follow their methods	<a href="#">CMS S&amp;C-12-07-Equip Maint Requirements</a>	4★
<b>ESRD</b> -Life Safety Code Effective Date	LSC to be used for new Dialysis Units after Feb, 2009, with exceptions	<a href="#">CMS S&amp;C-09-24-ESRD LSC Effective Date</a>	4★
<b>Evacuation Drills</b> in ICF/MRs	Must physically evacuate residents from facility; Not a "Defend in Place" facility	<a href="#">DSL-BQA-01-025-Evaucation Drill Requirements and Interpretations in ICF/MRs</a>	4★
<b>Exit Discharge Path, Surface</b>	Surveyor to judge if a type surface is acceptable under all weather conditions (Q2). FSES is not permitted as an equivalency	<a href="#">CMS S&amp;C-05-38-Wardrobe/Closet &amp; Canopy Sprinkler Requirements; Exit Discharge Surfacing</a>	4★
<b>Exit Discharge</b> to 40' from Bldg	Proper emergency lighting needed to at least 40' from the structure (K46)	<a href="#">DHS 08-001-Life Safety Information</a>	4★
<b>Exit Discharge</b> , Paved & FSES	A FSES can be used to eval compliance when an exit discharge path is not paved	<a href="#">CMS S&amp;C-07-05-Exit Discharge &amp; FSES</a>	4★
<b>Finish Documents</b>	Flame spread rating requirements clarified	<a href="#">CMS S&amp;C-11-07-Interior Finish Documents</a>	4★
<b>Fire Alarm Outage</b> Reporting	Policy template for reporting fire alarm outages	<a href="#">DHS 12-013-Fire Watch, Fire Plan and Fire Reporting</a>	4★
<b>Fire Drills</b> at various Times	Drills cannot be within the same 1-hr window (K50)	<a href="#">DHS 08-001-Life Safety Information</a>	4★
<b>Fire Plan</b> Requirements	Fire Response Plan code requirements	<a href="#">DHS 12-013-Fire Watch, Fire Plan and Fire Reporting</a>	4★
<b>Fire Report</b> Form, DQA	Report fires on DQA form	<a href="#">DHS 12-013-Fire Watch, Fire Plan and Fire Reporting</a>	4★
<b>Fire Reporting</b> , Procedures to Inform CMS	State Agency must notify CMS of facility fires that result in serious injury or death.	<a href="#">CMS S&amp;C-04-23-Procedures in Event of a Fire</a>	4★

\*Estimate of acceptability by CMS/DQA Surveyor

because of who generated:

#★ : 4 = CMS/DQA; 3=TJC/NFPA; 2=Other AHJ; 1=Non-AHJ

## INVENTORY OF CODE INTERPRETATIONS

Topic Keywords	Summary of Topic	Document & Link (Click to View)	AHJ*
<b>Fire Watch</b> Process	Template for Fire Watch rounds	<a href="#">DHS 12-013-Fire Watch, Fire Plan and Fire Reporting</a>	4★
<b>Fireplace, Direct-Vent</b> -Life Safety Code-2012 edition Waiver	Waivers possible to corridor chairs, open kitchens, direct-vent fireplaces, combustible decorations	<a href="#">CMS S&amp;C-12-21-LSC-Instructions Concerning Waivers</a>	4★
<b>Flame Spread</b> Documents	Flame spread rating requirements clarified	<a href="#">CMS S&amp;C-11-07-Interior Finish Documents</a>	4★
<b>FSES</b> , Canopy/Overhang Sprinkler Requirements	CMS requirements on sprinkling of canopies & overhangs; use of FSES & waivers	<a href="#">CMS S&amp;C-07-29-Canopy &amp; Overhang Sprinklers; Use of FSES</a>	4★
<b>FSES</b> , use for Unpaved <b>Exit Discharges</b>	A FSES can be used to eval compliance when an exit discharge path is not paved	<a href="#">CMS S&amp;C-07-05-Exit Discharge &amp; FSES</a>	4★
<b>Gaps in Corridor Doors</b>	Door gap clearances defined in sprinkled or non-sprinkled smoke compartments	<a href="#">CMS S&amp;C-07-18-Permitted Gaps in Corridor Doors</a>	4★
<b>Generator</b> , Remote Start	Remote start requirements for generators	<a href="#">DQA Interpretation NFPA 110-1</a>	4★
<b>Generator</b> , Shared Use	Generators used for non-emergency use, acceptable conditions	<a href="#">DQA Interpretation NFPA 99-2</a>	4★
<b>Generators</b> in ASC's	Requirements for Type I Essential Electrical Sys with generator in ASC's	<a href="#">CMS S&amp;C-07-21-Generators in ASC's</a>	4★
<b>Handrails</b> : Culture Change, Regulatory Q&A in LTC	Answers from CMS on questions they received on Handrails (Q6), Nurse Call Sys, Corridor Width, Egress Concealment	<a href="#">CMS S&amp;C-07-07-Culture Changes Regulatory Q&amp;A</a>	4★
<b>Hazardous Room</b> Rated Enclosure	Rated enclosure + sprinkler needed under New Constr of 1973, '81, '85, and '91 codes (K29)	<a href="#">DHS 08-001-Life Safety Information</a>	4★
<b>Incidental Air Movement</b> , Corridor	Clarifies acceptable amount of incidental air movement to/from corridor	<a href="#">CMS S&amp;C-06-18-Air Movement in Corridors; Plenum Waiver</a>	4★
<b>Interior Finish</b> Documents	Flame spread rating requirements clarified	<a href="#">CMS S&amp;C-11-07-Interior Finish Documents</a>	4★
<b>Kitchens Open</b> to Corridor-Life Safety Code-2012 edition Waiver	Waivers possible to corridor chairs, open kitchens, direct-vent fireplaces, combustible decorations	<a href="#">CMS S&amp;C-12-21-LSC-Instructions Concerning Waivers</a>	4★
<b>Life Safety Code</b> Adopted-2000 edition	NFPA 101-2000 ed adopted by CMS	<a href="#">DSL-BQA-03-006-CMS Adopts Life Safety Code, effective 3/11/2003</a>	4★
Life Safety Code, 2000 Adoption by CMS	CMS adopted the 2000 edition of NFPA 101, effective Mar 3, 2003; eliminates references to all earlier editions such as 1967, '73, '81, and '85.	<a href="#">CMS S&amp;C-03-21-Adoption of 2000 Life Safety Code</a>	4★
<b>Life Safety Code</b> , Dialysis Units, Effective Date	LSC to be used for new Dialysis Units after Feb, 2009, with exceptions	<a href="#">CMS S&amp;C-09-24-ESRD LSC Effective Date</a>	4★

\*Estimate of acceptability by CMS/DQA Surveyor

because of who generated:

#★ : 4 = CMS/DQA; 3=TJC/NFPA; 2=Other AHJ; 1=Non-AHJ

## INVENTORY OF CODE INTERPRETATIONS

Topic Keywords	Summary of Topic	Document & Link (Click to View)	AHJ*
<b>Life Safety Code</b> , State Fire Code Alternative	States may use their own adopted fire code in lieu of LSC-2000 if it adequately protects residents/patients	<a href="#">CMS S&amp;C-08-34-State Code Compliance in Lieu of LSC</a>	4★
<b>Life Safety Code</b> , Surveyor Reference Codes	CMS provides copies to State of NFPA 10, 13, 13D, 13R, 25, 30, 37, 70, 72, 80, 82, 90A, 90B, 96, 99, 101, 101A, 110, 220, 221 & Handbooks for NFPA 13, 72, 99, 101	<a href="#">CMS S&amp;C-04-29-LSC Surveyor Reference Materials</a>	4★
<b>Life Safety Code</b> -2012 edition Waivers	Waivers possible to corridor chairs, open kitchens, direct-vent fireplaces, combustible decorations	<a href="#">CMS S&amp;C-12-21-LSC-Instructions Concerning Waivers</a>	4★
<b>Maintenance of Equipment</b> -Hospital	Mfgr recommended frequencies may be adjusted for medical & facility equip; Must follow their methods	<a href="#">CMS S&amp;C-12-07-Equip Maint Requirements</a>	4★
<b>Major/Minor Modification</b> defined	Major & Minor Modification defined; replacement of a system is major	<a href="#">CMS S&amp;C-04-15-Major vs Minor Renovation</a>	4★
<b>Med Gas Cylinder</b> Operational Supply	CMS clarifications when less than 300 CF med gas used as an operational supply and not storage	<a href="#">CMS S&amp;C-07-10-Mec Gas Storage &amp; Use Considerations</a>	4★
<b>Med Gas Cylinder</b> Storage	Med gas cylinder storage overview	<a href="#">DQA Interpretation NFPA 99-3</a>	4★
<b>Nurse Call</b> : Culture Change, Regulatory Q&A in LTC	Answers from CMS on questions they received on Handrails, Nurse Call Sys (Q7), Corridor Width, Egress Concealment	<a href="#">CMS S&amp;C-07-07-Culture Changes Regulatory Q&amp;A</a>	4★
<b>Occupancy</b> Classifications-Hospital	Hospitals may be classified as new/existing Health Care, Ambulatory Health, Business, or other per LSC	<a href="#">CMS S&amp;C-11-05-LSC-Occupancy Classification Update</a>	4★
<b>Oxygen Room</b> Storage	Cannot have disposable O2 supplies in excess of a 1-week supply (K143)	<a href="#">DHS 08-001-Life Safety Information</a>	4★
<b>Plenum Waiver</b> , Corridor Neutral Airflow	Provides criteria for waiver when a corridor is used as a plenum (K67)	<a href="#">CMS S&amp;C-06-18-Air Movement in Corridors; Plenum Waiver</a>	4★
<b>Renovation Terms</b> defined	Major & Minor Modification defined; replacement of a system is major	<a href="#">CMS S&amp;C-04-15-Major vs Minor Renovation</a>	4★
<b>Safe Oxygen Use</b> & Storage in Ass't Living	Safety rules for Oxygen summarized	<a href="#">BQA 04-015-Safe Storage, Handling and Use of Oxygen in CBRF</a>	4★
<b>Smoke Alarms</b> , Non-Sprinkled LTC	Smoke detectors must be installed in resident rooms & common areas	<a href="#">CMS S&amp;C-05-25-Battery Smoke Detector</a>	4★
<b>Smoke Alarms</b> , Revised Terminology	CMS revised alarm terms and included Mfgr maintenance requirements in final rule requiring smoke alarms in facilities that are not fully sprinkled	<a href="#">CMS S&amp;C-07-01-Alcohol Based Hand Rubs-Final Rule &amp; Battery Smoke Alarms</a>	4★
<b>Smoke Barrier Door</b> Astragal	Gaps >1/8" require astragal (K27)	<a href="#">DHS 08-001-Life Safety Information</a>	4★
<b>Smoke Compartment Evac</b> in Fire Safety Plan	Must include smoke compartment evac in facility evacuation plan (K48)	<a href="#">DHS 08-001-Life Safety Information</a>	4★

\*Estimate of acceptability by CMS/DQA Surveyor

because of who generated:

#★ : 4 = CMS/DQA; 3=TJC/NFPA; 2=Other AHJ; 1=Non-AHJ

## INVENTORY OF CODE INTERPRETATIONS

Topic Keywords	Summary of Topic	Document & Link (Click to View)	AHJ*
<b>Smoke Detectors</b> Within 3' of Diffusers	Cannot have detector within 36" of supply or exhaust diffuser (K52)	<a href="#">DHS 08-001-Life Safety Information</a>	4★
<b>Sprinkler Install</b> in LTC	Mandatory full sprinkling by 8/13/2013 in all Long Term Care Facilities	<a href="#">CMS S&amp;C-09-04-LTC Mandatory Sprinkler Install Requirements</a>	4★
<b>Sprinkler Outage</b> Reporting	Policy template for reporting sprinkler outages	<a href="#">DHS 12-013-Fire Watch, Fire Plan and Fire Reporting</a>	4★
<b>Sprinkler Recall</b> in CBRF's	Central Sprinkler Recall, Expected Actions in CBRF's	<a href="#">DSL-BQA-02-014-Recall of Fire Protection Sys Sprinklers</a>	4★
<b>Sprinkler</b> , Canopy/ Overhang Requirements	CMS requirements on sprinkling of canopies & overhangs; use of FSES & waivers	<a href="#">CMS S&amp;C-07-29-Canopy &amp; Overhang Sprinklers; Use of FSES</a>	4★
<b>Suicide</b> Prevention Actions	Recommendations given for ceilings, sprinklers, door closers, towel bars, showers, plumbing fixtures, flooring, windows, cords, outlets, etc	<a href="#">DQA 11-019-Environmental Suicide Prevention</a>	4★
<b>Survey Protocols</b> for 2005 State Performance Review	CMS sets/revised 7 standards	<a href="#">CMS S&amp;C-05-03-State Performance Review Protocol</a>	4★
<b>Surveys</b> , Life Safety Code; CMS policies	Summary of CMS policies on state conducting of LSC surveys, including Waivers, FSES, Processes, etc	<a href="#">CMS S&amp;C-04-33-LSC Suveys; State Performance Standards</a>	4★
<b>Temporary Waiver</b> Processing, MidWest Consortium	States may authorize correction time extensions up to 6 months in LTC.	<a href="#">CMS MWC 06-05-Temporary Wiavers for LTC, Midwest Consortium</a>	4★
<b>Time Extention</b> , Plan of Correction	States may authorize correction time extensions (temporary waivers) up to 6 months in LTC.	<a href="#">CMS MWC 06-05-Temporary Wiavers for LTC, Midwest Consortium</a>	4★
<b>Toilets</b> (Uni-Sex), Conditions of use	LTC Waiver to allow shared toilets	<a href="#">DHS 07-016-Sharing of Toilet Facilities Between Sexes</a>	4★
<b>Ventilation</b> in CBRF	Ventilation requirements for Class C CBRF	<a href="#">DQA Interpretation CBRF 83-2</a>	4★
<b>Ventilator</b> Dependant Resident Requirements	Facility requirements prior to admitting a resident who is depenent on electrically powered equip	<a href="#">DSL-BQA-00-016-Planning to Admit Ventilator Dependent Residents or Persons with Related Conditions</a>	4★
<b>Waiver Processing</b> , LSC	All new, renewal and temporary Waivers of LSC conditions must be submitted to CMS-Regional Office for approval.	<a href="#">CMS MWC-04-01-LSC Waiver Processing</a>	4★
<b>Wardrobe</b> /Closet Sprinkler Requirements	CMS clarifications on providing fire protection to closets; wardrobes may be furniture (Q1)	<a href="#">CMS S&amp;C-05-38-Wardrobe/Closet &amp; Canopy Sprinkler Requirements; Exit Discharge Surfacing</a>	4★

\*Estimate of acceptability by CMS/DQA Surveyor

because of who generated:

#★ : 4 = CMS/DQA; 3=TJC/NFPA; 2=Other AHJ; 1=Non-AHJ