LLSC Form

		EESC 1 G1
Receptacle Tests-Install & Service (Patient Care Areas)		Receptacl
Facility:	ı	Tests
		7

Inspector's Signature:	DATE INSPECTED		Page 1	
All receptacles in patient care areas (normal & emergency powered) must be tested after initial installation, replacement, or				
service, and results documented. Provide this form to electrical staff for completion after all construction/service work.				
TEST PROCEDURES: In each area, ID each outlet starting on the LH side of the main entry door	and proceed counter-clockwise back to the entry door; test			
each individual outlet for the following 4 conditions. Record each on a separate line. Use added	pages as needed.			
a. Visually inspect the device and cover that they are intact and in good condition (enter Pass/Fail evaluation in Col "D")				
b. Use a receptacle tester and verify continuity of the ground and polarity (enter Pass/	Fail evaluation in Col "E" & 'F')	§6.3.3.2	2.2	
c. Use a receptacle tester and verify polarity (enter Pass/Fail evaluation in Col "E" & 'F'		§6.3.3.2	2.3	
d. Use a ground blade tension tester and verify tension is no less than 4 oz. (enter Pass	s/Fail evaluation in Col "G')	§6.3.3.2	2.4	
IF ANY TEST FAILS ENTED IN COLUMN A FULL DESCRIPTION OF ISSUE METHOD & DATE	OF CORRECTION & WILLO CORRECTED	TJC EC: non	ne	
IF ANY TEST FAILS, ENTER IN COL "H" A FULL DESCRIPTION OF ISSUE, METHOD & DATE	OF CORRECTION & WHO CORRECTED			

А	В	C	D	E	F	G	Н	I
				"a"	"b"		"d"	
		*TYPE	DEVICE ID	Physical	Ground	"c"	Tension ≥ <u>4</u>	
		OUTLET	(start L of door &	<u>Condition</u>	<u>Continuity</u>	Polarity Check	<u>oz</u>	If Fail, Describe Corrective Action,
ROOM #	ROOM NAME		test all, ccw)	Pass/Fail	Pass/Fail	Pass/Fail	Pass/Fail	Who & Date
1								
2								
3								
4								
4								
5								
6								
7								
8								
9								
10								

^{*}Type Outlet: Enter HG=Hospital Grade; S=Single; D=Duplex; Q=Quad; M=Multiple (over 4) - Every plug-in location must be individually tested © Lauzon Life Safety Consulting, Jan 2020